

**ZARZYCKI CONTRACTING INC.**  
**SPRINKLERS AND FIRE PROTECTION**

35 GLASGOW STREET SOUTH, CONESTOGO, N0B 1N0  
(519) 748-7961

May 1, 2025

HYDRANT FLOW TEST- 50 Emma St. Grand Valley

A hydrant flow test was performed on Wednesday April 30, 2025 @ 4:45 pm  
Flowing Hydrant-Riverview Apartments. 71 Emma St  
Static Hydrant- Beside Grand Valley Car Wash

Static Pressure 93 psi

Flowing one 2 1/2" hydrant port.

Pitot- 61 psi

Flow- 1,457 USGPM

Residual- 90 psi

Flowing two 2 1/2" hydrant ports

Pitot-45 psi , 45 psi

Flow- 1,251 & 1,251= 2,502 USGPM

Residual- 83 psi

GPM is taken from NFPA 291 2002 edition, table 4.10.1(a)

Any questions please call.

Warm Regards,



Mike Zarzycki

[zarconfire@rogers.com](mailto:zarconfire@rogers.com)